



North Springs Improvement District

Five-Year Surface Water Permit Renewal

Purpose: The purpose of the Five-Year Surface Water Permit Renewal program is to provide the North Springs Improvement District (the “District”) with the information it needs to ensure the permitted surface water management system is being maintained and operating as permitted by the THE DISTRICT and that if repairs are required, that the Permittee make the necessary repairs to restore the water management system to its permitted state.

Permittee’s Responsibilities: It shall be the responsibility of the Permittee to provide for an inspection and subsequent report every five (5) years from permit issuance date, certified by a Florida professional registered engineer, that the stormwater management system is operating as permitted by the District. In addition, the Permittee will state in the report what operational maintenance has been performed on the system. Reports shall be submitted on form: STORMWATER INSPECTION REPORT (See Exhibit A).

Initial Implementation of Five-Year Surface Water Permit Renewal Program: Upon adoption of the proposed Five-Year Surface Water Permit Renewal Program, the District will contact all Permittees having received a surface water management permit in excess of 5 years from date of implementation, according to the District’s records, and notify the same of the new Five-Year Surface Water Permit Renewal requirement.

Subsequent to Implementation: Subsequent to the initial implementation of the District’s Five-Year Surface Water Permit Renewal Program, the District will maintain a list of all expiring permits and contact the Permittee ninety (90) days prior to the expiration of the surface water management permit and advise the Permittee of the expiration date and the required re-inspection of the permitted system.

Enforcement: Failure of the property owner to re-certify to the District compliance with the proposed Five-Year Surface Water Permit Renewal Program will result in the District’s revocation of the Surface Water Management Permit and notification to the South Florida Water Management District and the local governing authorities of the same.

Fees: The renewal fee of \$500.00 must to be submitted at the time of certification. Please note that failure to comply with this requirements may result in warnings followed by violations fee in the amount of \$200.00. Upon final warning, the District shall have the required Certification completed by a licensed Engineer and fees will be charged to and collected from the applicant/owner and possible lien on property may be filed to recover costs.



EXHIBIT 7

NORTH SPRINGS IMPROVEMENT DISTRICT STORMWATER INSPECTION REPORT FOR COMPLETION BY REGISTERED PROFESSIONALS

DISTRICT PERMIT NO: _____ ISSUE DATE: _____
PROJECT NAME: _____
RESPONSIBLE MAINTENANCE ENTITY: _____
CONTACT PERSON: _____
PHONE: _____ FAX: _____
MAILING ADDRESS: _____

I CERTIFY THAT BASED ON AN INSPECTION BY ME OR MY DESIGNATED REPRESENTATIVE, CONDUCTED ON _____, THAT THE DRAINAGE SYSTEM FOR THE ABOVE-REFERENCED PROJECT HAS NOT BEEN MODIFIED SINCE THE AS-BUILT DRAWINGS WERE PREPARED, EXCEPT AS NOTED BELOW:

I FURTHER CERTIFY THAT:

1. ALL CATCH BASINS, GRATES, STORM MANHOLE COVERS AND OUTFALLS ARE FREE OF OBSTRUCTIONS.
2. ALL CATCH BASINS WERE PROBED DURING THE INSPECTION AND ARE SUBSTANTIALLY FREE OF MUD, DEBRIS, SILT, ETC.
3. THERE ARE NO AREAS OF SUNKEN PAVEMENT THAT IN MY PROFESSIONAL OPINION ARE LIKELY TO BE THE RESULT OF A FAILURE OF THE DRAINAGE SYSTEM.
4. THERE ARE NO DETERIORATED HEADWALLS OR BROKEN GRATES.
5. APPROVED WEIRS AND BAFFLES ARE IN PLACE.
6. SWALES AND RETENTION/DETENTION AREAS HAVE NOT BEEN MODIFIED.
7. THE SYSTEM HAS NOT BEEN EXPANDED.

NOTES:

1. THE TERM "SUBSTANTIALLY FREE" SHALL MEAN THAT THE DEPTH OF MATERIAL IN A PIPE SHALL NOT EXCEED 5% OF THE DIAMETER OF THE PIPE AND THE DEPT OF MATERIAL IN A SUMP SHALL NOT EXCEED 5% OF THE DISTANCE FROM THE BOTTOM OF THE STRUCTURE TO THE LOWEST PIPE INVERT.
2. THE ENGINEER'S INSPECTION SHALL INCLUDE BUT NOT BE LIMITED TO A VISUAL INSPECTION OF ALL OUTFALLS, GRATES, STORM MANHOLE COVERS, WEIRS, MANHOLES AND CATCH BASINS AND PROBING ALL MANHOLES AND CATCH BASINS. THE INSPECTION OF PIPES IS ONLY REQUIRED IF THE ENGINEER CONCLUDES THAT THERE IS EVIDENCE TO WARRANT IT.
3. THIS CERTIFICATION IS TO INCLUDE A BRIEF SUMMARY OF LANDSCAPING THAT THE ENGINEER OBSERVES OVER DRAINAGE PIPES.

LIST MODIFICATIONS: _____

NAME (please print)

COMPANY NAME

COMPANY ADDRESS

CITY, STATE, ZIP CODE

TELEPHONE NUMBER

SIGNATURE OF PROFESSIONAL ENGINEER

FLORIDA REGISTRATION NUMBER

DATE

(Affix Seal)

WITHIN 30 DAYS OF INSPECTION OF THE SYSTEM, SUMIT TWO COPIES OF THIS FORM TO:

NORTH SPRINGS IMPROVEMENT DISTRICT
ATTN: FIVE YEAR SURFACE WATER PERMIT RENEWAL
9700 NW 52nd Street
CORAL SPRINGS, FL 33076